

Attestation of Conformity no. 124-26183-A1

FORCE Technology has performed compliance testing on electrical products since 1967. FORCE Technology is an accredited test house according to EN17025 and participates in international standardization with organizations such as CEN/CENELEC, IEC/CISPR and ETSI. This attestation of conformity with the below mentioned standards and/or normative documents is based on accredited tests and/or technical assessments carried out at FORCE Technology.

| <p>Attestation holder</p> <p>C P In Stainless ApS Dalvangen 1 9800 Hjørring DENMARK</p> | | | | | | | |
|--|-------------|----------|-------------|----------------|------|----------------|------|
| <p>Product identifications</p> <p>Type A cabinet, versions according to technical documentation: 250x250x150 mm, 300x300x150 mm, 300x300x220 mm, 300x400x220 mm, 400x400x220 mm, 400x600x220 mm, 500x500x220 mm, 600x400x220 mm, 600x600x220 mm & 600x600x320 mm</p> | | | | | | | |
| <p>Manufacturer</p> <p>C P In Stainless ApS</p> | | | | | | | |
| <p>Technical documentation</p> <p>Assessment no. 124-26183-A1 IP66 test of type A cabinet, Project no.: 124-26183, report no.: 124-26183-1 dated 25 September 2024 Technical document: 0_C P Basic vægskabe, dated 16-04-2024</p> | | | | | | | |
| <p>Standards/Normative documents</p> <table border="1"> <thead> <tr> <th>Standard</th> <th>Test method</th> </tr> </thead> <tbody> <tr> <td>IEC 60529:2013</td> <td>IP6X</td> </tr> <tr> <td>IEC 60529:2013</td> <td>IPX6</td> </tr> </tbody> </table> <p>The product identified above has been assessed and complies with the specified standards/normative documents. The attestation does not include any market surveillance. It is the responsibility of the manufacturer that mass-produced apparatus have the same properties and quality. This attestation does not contain any statements pertaining to the requirements pursuant to other standards, directives or laws other than the above mentioned.</p> | | Standard | Test method | IEC 60529:2013 | IP6X | IEC 60529:2013 | IPX6 |
| Standard | Test method | | | | | | |
| IEC 60529:2013 | IP6X | | | | | | |
| IEC 60529:2013 | IPX6 | | | | | | |
| <p>Signature</p> | | | | | | | |